


S.J.1 (E)

Icc: 6kA
415V - 50Hz
Class II
TN-S
IP43 - IK08



CONECTOR NUMBER	---
CIRCUIT NUMBER	---
PHASE	---
POWER (kVA/kW)	---
CABLE [mm²]	---
DESTINATION	Surge Arrester


SL1	L1	L2	L3	L4
P1	P2	P3	P4	---
Cu/ XLPE/ PVC 5G1.5 mm²	Cu/ XLPE/ PVC 5G1.5 mm²	Cu/ XLPE/ PVC 5G1.5 mm²	Cu/ XLPE/ PVC 5G1.5 mm²	---
Emergency Lights	Lighting Corridor	Lighting Bathroom	Lighting On-call Room	Reserve Not Equipped

S1	S2	S3	S4
P1	P2	---	---
Cu/ XLPE/ LSZH 3G2.5 mm²	---	---	---
Power Outlet On-call Room	Reserve Not Equipped	Reserve Not Equipped	Reserve Not Equipped

P1	P2	P3	P4	P5	P6
P1	P2	P3	P4	P5	P6
Cu/ XLPE/ LSZH 3G2.5 mm²	Cu/ XLPE/ LSZH 3G2.5 mm²	Cu/ XLPE/ LSZH 3G2.5 mm²	---	---	---
Power Equipment Ceiling Fans	Power Equipment AC Outdoor Unit	Power Equipment AC Outdoor Unit	Reserve Equipped	Reserve Equipped	Reserve Not Equipped

S.J.2 (E)

Icc: 6kA
415V - 50Hz
Class II
TN-S
IP43 - IK08



CONECTOR NUMBER	---
CIRCUIT NUMBER	---
PHASE	---
POWER (kVA/kW)	---
CABLE [mm²]	---
DESTINATION	Surge Arrester


SL1	L1	L2	L3	L4
P1	P2	P3	P4	---
Cu/ XLPE/ PVC 5G1.5 mm²	Cu/ XLPE/ PVC 5G1.5 mm²	Cu/ XLPE/ PVC 5G1.5 mm²	---	---
Emergency Lights	Lighting Corridor	Lighting Showers	Lighting On-call Room	Reserve Not Equipped

S1	S2	S3	S4
P1	P2	P3	---
Cu/ XLPE/ LSZH 3G2.5 mm²	Cu/ XLPE/ LSZH 3G2.5 mm²	Cu/ XLPE/ LSZH 3G2.5 mm²	---
Power Outlet On-call Room	Power Outlet On-call Room	Power Outlet On-call Room	Reserve Not Equipped

P1	P2	P3	P4	P5	P6
P1	P2	P3	P4	P5	P6
Cu/ XLPE/ LSZH 3G2.5 mm²	Cu/ XLPE/ LSZH 3G2.5 mm²	Cu/ XLPE/ LSZH 3G2.5 mm²	---	---	---
Power Equipment Ceiling Fans	Power Equipment AC Outdoor Unit	Power Equipment AC Outdoor Unit	Reserve Equipped	Reserve Equipped	Reserve Not Equipped

S.J.3 (E)

Icc: 6kA
415V - 50Hz
Class II
TN-S
IP43 - IK08



CONECTOR NUMBER	---
CIRCUIT NUMBER	---
PHASE	---
POWER (kVA/kW)	---
CABLE [mm²]	---
DESTINATION	Surge Arrester


SL1	L1	L2	L3	S1	S2	S3
P1	P2	P3	P4	P1	P2	P3
Cu/ XLPE/ PVC 5G1.5 mm²	Cu/ XLPE/ LSZH 3G1.5 mm²	Cu/ XLPE/ LSZH 3G1.5 mm²	Cu/ XLPE/ LSZH 3G2.5 mm²	---	---	---
Emergency Lights	Lighting / Wash Area	Lighting Laundry / Dry Area	Reserve Not Equipped	Power Outlet	Reserve Equipped	Reserve Not Equipped

E1	E2	E3	E4	E5	E6
P1	P2	P3	P4	P5	---
Cu/ XLPE/ LSZH 3G2.5 mm²	Cu/ XLPE/ LSZH 3G2.5 mm²	Cu/ XLPE/ LSZH 3G2.5 mm²	---	---	---
Power Equipment Ceiling Fans	Power Equipment Electric Heater	Power Equipment AC Outdoor Unit	Reserve Equipped	Reserve Equipped	Reserve Not Equipped

E7	E8	E9	E10	E11	E12
P1	P2	P3	---	---	---
---	---	---	---	---	---
Reserve Equipped	Reserve Equipped	Reserve Equipped	Reserve Not Equipped	Reserve Not Equipped	Reserve Not Equipped

S.J.4 (E)

Icc: 6kA
415V - 50Hz
Class II
TN-S
IP43 - IK08



CONECTOR NUMBER	---
CIRCUIT NUMBER	---
PHASE	---
POWER (kVA/kW)	---
CABLE [mm²]	---
DESTINATION	Surge Arrester

SL1	L1	L2	S1	S2	S3
P1	---	P3	P1	---	---
Cu/ XLPE/ PVC 5G1.5 mm²	---	Cu/ XLPE/ LSZH 3G2.5 mm²	---	---	---
Lighting	Reserve Equipped	Reserve Not Equipped	Power Outlet	Reserve Equipped	Reserve Not Equipped

E1	E2	E3	E4	E5	E6
P1	P2	P3	P4	---	---
Cu/ XLPE/ LSZH 3G2.5 mm²	---	---	---	---	---
Power Equipment AC Outdoor Unit	Reserve Equipped	Reserve Equipped	Reserve Not Equipped	Reserve Not Equipped	---

